



NOTES

- 1.) All vertical panel joints shall occur over, and be fastened to common studs. R602.10.8
- 2.) All horizontal joints shall occur over, and be fastened to, common blocking. of a minimum 2" nominal thickness
- 3.) See R602.10.1.5 for braced wall line spacing
- 4.) Panel method R602.10.2 - method 3 depicted
- 5.) For masonry veneer see R602.12 for additional bracing requirements