



Figure 1 Lavatory Clearances

### ANSI 606 and 306.3

The following knee clearances is required underneath the lavatory: 27" from the floor to the underside of the lavatory which extends 8" minimum measured from the front edge underneath the lavatory back towards the wall; if a minimum 9" of toe clearance is provided, a maximum of 6" for the 48" of clear floor space required at the fixture may extend into the toe space.

Pipe protection per Ansi 606.6

Faucets shall comply with Section 309 and reach ranges per 308.

Floor surfaces shall be stable, firm and slip resistant. Ansi 302.1

Hand-operated metering faucets shall remain open for 10 seconds-

See ANSI 606.4.