

## TEMPERED GLAZING REQUIREMENTS

### R308.4 Hazardous locations, Item #7:

Glazing in an individual fixed or operable panel, other than those locations described in Items 5 and 6 above, that meets all of the following conditions:

- 7.1 Exposed area of an individual pane larger than 9 square feet.
- 7.2 Bottom edge less than 18 inches above the floor.
- 7.3 Top edge more than 36 inches above the floor.
- 7.4 One or more walking surfaces within 36 inches horizontally of the glazing.

