

R613.2 Window Sills. In Dwelling units where operable window is located more than 72" above finished grade or surface below, the lowest part of the clear opening of the window shall be a minimum of 24" above the finished floor of the room in which the window is located.

**EXCEPTION:**

1. Windows whose openings will not allow a 4" diam. sphere to pass through when the opening is in its largest opened position.
2. Openings that are provided with window guards that comply with ASTM F 2006 or F2090.

