




Southwest Washington Chapter of ICC

This construction detail is accepted as meeting the minimum standard of construction as based upon the 2003 IRC / WAC 51-51 requirements and is accepted in the following regional jurisdictions

Cities of; Camas, Centralia, Kalama, Ridgefield, Castle Rock, Vancouver, Washougal, Winlock, Woodland, Longview, Battle Ground,
Counties of; Clark, Cowlitz, Skamania, Lewis

stud width

IRC 602.6(1) INTERIOR NON-LOAD BEARING WALLS



TOP PLATES

40% OF STUD WIDTH MAX




R602.6 Drilling and notching - studs.

Studs in nonbearing partitions may be notched to a depth not to exceed 40 percent of a single stud width.


Any NON LOAD BEARING stud may be bored or drilled, provided that the diameter of the resulting hole is no greater than 60 percent of the stud width

(SEE FIGURE R602.6(2) 2003 IRC, the edge of the hole is no closer than 5/8 inch (15.9 mm) to the edge of the stud, and the hole is not located in the same section as a cut or notch.

NO CLOSER THAN 5/8" TO EDGE OF STUD



BORED OR DRILLED HOLES 60% OF STUD WIDTH MAX



BORED HOLES SHALL NOT BE LOCATED IN THE SAME CROSS SECTION OF CUTS OR NOTCHES IN STUDS

R602.6(2) 2/04