



NOTE: BRACED WALL PANELS

WSP 4'-0" panel of min. 3/8" cdx plywood
w/ 6d nails @ 6" o.c. edges & 12" o.c. field
-Table R602.3(3).

Alternate: GB 8'-0" panel one side or 4'-0"
panel each side of 1/2" gypsum board-studs
spaced max. 24" o.c. and nailed at 7" o.c.
edge & field. w/ 5d cooler nails-Table
R702.3.5.

continuous footing w/ #4 rebar
continuous min. 3" from the bottom of
footing R403.1.3

NOTE:

R403.1.2- all required
interior braced wall panels
shall be supported on
footings at intervals not
exceeding 50'-0"

Interior Braced Wall Panels (w/ joists or rafters parallel to panels)