



NOTE: BRACED WALL PANELS

WSP 4'-0" panel of min. 3/8" cdx plywood w/6d nails @ 6" o.c. edges & 12" o.c. field -Table R602.3(3).

Alternate: GB 8'-0" panel one side or 4'-0" panel each side of 1/2" gypsum board-studs spaced max. 24" o.c. and nailed at 7" o.c edge & field. w/5d cooler nails-Table R702.3.5.

NOTE:
R403.1.2- all required interior braced wall panels shall be supported on footings at intervals not exceeding 50'-0"

Interior Braced Wall Panels (w/joists or rafters perpendicular to panels)