


# Southwest Washington Chapter of ICC This construction detail is illustrative of the minimum standard


of construction based upon the 2021 IRC / WAC 51-51

Visit our web site at: www.sww-icc.org




## M1804.2.6 (3)

The vent termination point shall not be located closer than 3'-0" to an interior corner formed by two walls perpendicular to each other.



M1804.2.6 (4)

The bottom of the vent termination shall be located at least 12" above finish grade level



Gas Meter Elevation View

## M1804.2.6 (5)

The vent termination shall not be mounted directly above or within 3'-0" horizontally of an oil tank vent or gas meter.

Also, contact the local gas purveyor

### M1804.2.6 (6)

Power exhauster termination shall be not less than 10'-0" from the lot line and adjacent buildings.

### M1804.2.6 (7)

The discharge shall be directed away from the building.