

TEMPERED GLAZING REQUIREMENTS

R308.4 Hazardous locations, The locations specified in Sections R308.4.1 through R308.4.7 shall be considered to be specific hazardous locations for the purposes of glazing. R308.4.3 Glazing in windows. Glazing in an individual fixed or operable panel that meets all of the following conditions shall be considered to be a hazardous location and would require either safety glazing or a protective bar.

1. Exposed area of an individual pane larger than 9 square feet.
2. Bottom edge less than 18 inches above the floor.
3. Top edge more than 36 inches above the floor.
4. One or more walking surfaces within 36 inches horizontally of the glazing.

